


FICHES DE COTES RACCORDS

Fiche Technique

8.6

RÉDUCTIONS CONCENTRIQUES

Mâle - Femelle



D-d	Dn	Référence	E	L
90-25	80-20	HRDC9025	18,5	51
90-32	80-25	HRDC9032	22	51
125-63	110-50	HRDC1263	38,5	69,5
125-75	110-65	HRDC1275	44,5	69,5
160-110	150-100	HRDC1611	62	87
160-125	150-110	HRDC1612	69	87

MANCHONS PVCC POUR THERMOCOUPLE


Femelle - Femelle



D	Dn	Référence	Z	E	L	A
16	10	HMI16	27	15	57	30
20	15	HMI20	27	17	61	39
25	20	HMI25	27	19,5	66	45
32	25	HMI32	27	23	73	53

COUDES PVCC A INSERT LAITON

Femelle - Femelle - G à visser




D	Dn	Référence	Z	E	L	A	K	G
32	25	H4MI32	17	23	77,5	44	20,5	1/2"
40	32	H4MI40	21,5	27	90	54	24,5	1/2"
50	40	H4MI50	26	32	105	65	30	1/2"
63	50	H4MI63	32	38	124	80	37	1/2"

Raccordement : voir Fiche 4.4

TÉS REDUITS TARAUDÉS 90°

Femelle - Femelle - G à visser



D	G	Référence	Dn	Z	E	A	A1	L	Z1	L1
32	1/2"	HTGRL3212	25	17	23	43	46	80	28	47
40	1/2"	HTGRL4012	32	21,5	26,5	54	47	96,5	28	47
50	1/2"	HTGRL5012	40	26	33	65	47	118,5	28,5	47
63	1/2"	HTGRL6312	50	33	38,5	79,5	47	142,5	35	53,5
32	3/4"	HTGRL3234	25	17	23	43	46	80	28	47
40	3/4"	HTGRL4034	32	21,5	26,5	54	47	96,5	28	47
50	3/4"	HTGRL5034	40	26	33	65	47	118,5	28,5	47
63	3/4"	HTGRL6334	50	33	38,5	79,5	47	142,5	35	53,5

Raccordement : voir Fiche 4.4

TÉS REDUITS TARAUDÉS 90°

Femelle - G à visser



D	G	Référence	Dn	Z	E	A	A1	L	Z1	L1
40	3/4"	HTGR4034	32	21,7	26,5	54,1	40	96,4	24	42,3
50	3/4"	HTGR5034	40	26,2	31,2	64,8	40	118	28,7	46,9
63	3/4"	HTGR6334	50	33	38,3	79,7	40	142,7	36	54,3

Raccordement : voir Fiche 4.4